

DUPLEXbase PT 1800

DUPLEXbase PT



PERFORMANCE

| Fans | | Supply Air | Extract Air |
|----------------------------------|---------------|------------|-------------|
| Air volume @200Pa | m³/hr / l/sec | 1800 / 500 | 1800 / 500 |
| Nominal voltage | V | 230 | 230 |
| Power input (at operation point) | kW | 0.49 | 0.44 |
| Max power input | kW | 0.78 | 0.78 |
| Max current | A | 3.9 | 3.9 |
| SFP | W/l/s | 0.97 | 0.87 |
| Fan type | | EC | EC |

Note: The figures above have been measured at 1800 m³/h and 200 Pa. Please use the Duplexvent Selection Software to calculate measurements at other performance levels.

The unit consist of fans equipped with the EC technology. These fans have modulating speed control throughout the marked area.

| Heat Recovery | | Supply Air | Extract Air |
|--|---------------|----------------------|-------------|
| Air volume @200Pa | m³/hr / l/sec | 1800 / 500 | 1800 / 500 |
| Temperature at inlet | °C | -5 | 20 |
| Temperature at outlet | °C | 16 | 3 |
| Humidity at inlet | % RH | 90 | 40 |
| Humidity at outlet | % RH | 20 | 100 |
| Heat recovery efficiency winter / summer | % | 83 / 79 | |
| Performance in winter / summer | kW | 12.9 / 2.9 | |
| Condensation | l/h | 2.8 | |
| Type of heat exchanger | | Counterflow, Plastic | |
| Part No. | | 90001427 | |

Note: The figures above have been measured at 1800 m³/h and 200 Pa. Please use the Duplexvent Selection Software to calculate measurements at other performance levels.

| Sound Power Level LwA (dB) | Total | 63 Hz | 125 Hz | 250 Hz | 500 Hz | 1 kHz | 2 kHz | 4 kHz | 8 kHz | dB (A) |
|--|-------|-------|--------|--------|--------|-------|-------|-------|-------|--------|
| Outdoor air e1 | 60 | 54 | 44 | 54 | 51 | 51 | 51 | 33 | <25 | |
| Supply air e2 | 81 | 57 | 62 | 76 | 76 | 74 | 69 | 63 | 57 | |
| Extract air i1 | 59 | 54 | 44 | 54 | 51 | 50 | 51 | 31 | <25 | |
| Exhaust air i2 | 79 | 55 | 60 | 75 | 75 | 72 | 68 | 61 | 56 | |
| Breakout noise | 59 | 36 | 39 | 58 | 42 | 45 | 41 | 39 | <25 | |
| Sound Pressure Level LpA (dB) measured at 3m | 39 | <25 | <25 | 38 | <25 | 25 | <25 | <25 | <25 | |

Note: The figures above have been measured at 1800 m³/h and 200 Pa. Please use the Duplexvent Selection Software to calculate measurements at other performance levels.

KEY FEATURES


- Air volume up to 1800 m³/h at 200 Pa according to ErP 2018
- Excellent thermal efficiency, up to 90%
- Compact design and high flexibility in unit orientation
- Low SFP with energy saving EC fans
- Low noise, refer to NR35 and BB93 standards
- Excellent thermal insulation (class T2, TB1)
- 100% adjustable digital controller with Internet and BMS connection
- BREEAM, Part L, Volume 2 and ErP 2018 compliant
- 2 year warranty+

OPTIONAL FEATURES


- Modulating control based on flow (constant flow function)
- Modulating control based on pressure (0-10V input)
- Pre and post-heating coils
- Cooling coils
- CO₂ monitors

More options available using our Duplexvent selection software.


AIR FLOW CURVE



POWER CONSUMPTION



HEAT RECOVERY EFFICIENCY




Note: Green area denotes power consumption range. Power consumption depends on system installation.

+excludes motors. Motor warranty one year from date of purchase.




Winter Operation:

e1 - outdoor air (ODA)
e2 - supply air (SUP) i1 - extract air (ETA)
i2 - exhaust air (EHA)



Note: AHU functions diagram. Inlet and outlet location may differ from actual position and port configuration.



Supply


| | Description | t [°C] | RH [%] |
|----|---------------|--------|--------|
| e1 | Outdoor Air | -5.0 | 90 |
| eR | Heat Recovery | 16.3 | 19 |

Exhaust


| | Description | t [°C] | RH [%] |
|----|---------------|--------|--------|
| i1 | Extract Air | 20.0 | 40 |
| i2 | Heat Recovery | 3.2 | 96 |

Summer Operation:

e1 - outdoor air (ODA)
e2 - supply air (SUP) i1 - extract air (ETA)
i2 - exhaust air (EHA)



Note: AHU functions diagram. Inlet and outlet location may differ from actual position and port configuration.



Supply

| | Description | t [°C] | RH [%] |
|----|---------------|--------|--------|
| e1 | Outdoor Air | 32.0 | 35 |
| eR | Heat Recovery | 28.0 | 44 |

Exhaust

| | Description | t [°C] | RH [%] |
|----|---------------|--------|--------|
| i1 | Extract Air | 26.0 | 50 |
| i2 | Heat Recovery | 31.2 | 37 |




DUPLEXbase PT 1800

DUPLEXbase PT

OPTIONAL ACCESSORIES

PRE-HEATING


| Electric pre-heater | | Supply Air |
|-----------------------|----------------------------|------------|
| Air volume @200Pa | m ³ /hr / l/sec | 1800 / 500 |
| Max. heating capacity | kW | 4.4 |
| Voltage | V | 400 |
| Heating coil type | | built-in |



| Electric pre-heater | | Supply Air |
|-----------------------|----------------------------|------------|
| Air volume @200Pa | m ³ /hr / l/sec | 1800 / 500 |
| Max. heating capacity | kW | 6 |
| Voltage | V | 400 |
| Connection ports | mm | Ø 315 |
| Heating coil type | | external |

POST HEATING

| Electric post-heater | | Supply Air |
|--|----------------------------|------------|
| Air volume @200Pa | m ³ /hr / l/sec | 1800 / 500 |
| Temperature at inlet (upstream of heater) | °C | 16 |
| Temperature at outlet (downstream of heater) | °C | 19 |
| Heating capacity | kW | 2.3 |
| Max. heating capacity | kW | 4.0 |
| Voltage | V | 400 |
| Heating coil type | | built-in |



B Sludge valve plug
C Sludge valve plug

Hydraulic kit: RE-HW3.LM24A-SR

IVAR.MIX4, Kv 12, 1"

2)
2)

LM24A-SR

1)
1)

1" female

1)
1)

WILO YONOS PARA RS 20/6- RKC

1)
1)

Others

L Water bypass

3)



1 - Delivered separately

3)

2 - Fitted and connected

3)

3 - Not part of delivery, recommended



Note: The figures to the left have been measured at 1800 m³/h and 200 Pa. Please use the Duplexbase Selection Software to calculate measurements at other performance levels.

DUPLEXbase PT 1800


DUPLEXbase PT

POST HEATING continued



| Water heating coil | | Supply Air |
|--|----------------------------|-------------|
| Air volume @200Pa | m ³ /hr / l/sec | 1800 / 500 |
| Temperature at inlet (after heat recovery) | °C | 16 |
| Temperature at outlet (downstream of heater) | °C | 20 |
| Heating capacity | kW | 2.3 |
| Heating medium temperature drop | °C | 70 / 20 |
| Medium flow (from source) | l/h | 39 |
| Medium-side pressure drop in heat exchanger / in valve | kPa | 2.40 / 0.38 |
| Connection dimension (hydraulic kit) | | 1" female |
| Coil capacity | l | 2.0 |
| Heating coil type | | external |
| Connection dimension | | 1" female |

Note: The figures above have been measured at 1800 m³/h and 200 Pa. Please use the Duplexvent Selection Software to calculate measurements at other performance levels.

OPTIONAL ACCESSORIES



- B** Sludge valve
C Sludge valve
Hydraulic kit: R-CW3.TR 24-SR
D 3-way ball valve
E Actuator
F Globe valve
G Pump
L Water bypass
K Coil water/ethylene glycol
 1 - Delivered separately
 2 - Fitted and connected
 3 - Not part of delivery



COOLING


| Water cooling coil | | Supply Air |
|--|----------------------------|--------------|
| Air volume @200Pa | m ³ /hr / l/sec | 1800 / 500 |
| Temperature at inlet (after heat recovery) | °C | 27 |
| Temperature at outlet (downstream of cooling coil) | °C | 17 |
| Inlet relative humidity (after heat recovery) | % RH | 46 |
| Outlet relative humidity (downstream the cooling coil) | % RH | 84 |
| Cooling capacity | kW | 7 |
| Condensate production | l/h | 1 |
| Water temperature drop | °C | 6 / 13 |
| Medium flow (at max. capacity) | l/h | 910 |
| Medium-side pressure drop in heat exchanger / in valve | kPa | 35.10 / 0.14 |
| Connection dimension | | 1" female |
| Coil capacity | l | 2.3 |
| Heating coil type | | built-in |

Note: The figures above have been measured at 1800 m³/h and 200 Pa. Please use the Duplexvent Selection Software to calculate measurements at other performance levels.

DX COIL

| DX coil | Supply |
|--|----------------------------|
| Air volume @200Pa | m ³ /hr / l/sec |
| 1800 / 500 | |
| Temperature at inlet (after heat recovery) | °C |
| 27 | |
| Temperature at outlet (downstream of cooling coil) | °C |
| 16 | |
| Inlet relative humidity (after heat recovery) | % RH |
| 46 | |
| Outlet relative humidity (downstream the cooling coil) | % RH |
| 84 | |
| Cooling capacity | kW |
| 7.71 | |
| Condensate production | l/h |
| 2 | |
| Refrigerant type | R32 |
| Evaporating temperature | °C |
| 10 | |
| Coil capacity | l |
| 3.0 | |
| Heating coil type | |
| | built-in |


COOLING CAPACITY



Note: The figures above have been measured at 1800 m³/h and 200 Pa. Please use the Duplexvent Selection Software to calculate measurements at other performance levels.

DIMENSIONS

AHU size length 2150 mm
height (without AHU feet) 1600 mm
depth 680 mm
Weight approx. 409 kg



| Connections | Type | Dimensions | Optional components |
|-------------|-----------------------|--------------------|-------------------------------|
| e1 | e1- outdoor air (ODA) | 250 x 300 mm | shutoff damper |
| e2 | e2- supply air (SUP) | 250 x 300 mm | 4x M6 thread for 20 mm flange |
| i1 | i1- extract air (ETA) | 250 x 300 mm | 4x M6 thread for 20 mm flange |
| i2 | i2- exhaust air (EHA) | 250 x 300 mm | 4x M6 thread for 20 mm flange |
| K | condensate drain | 2x Ø 16 mm / 22 mm | |

Notice:

- Door – 2 parts
- Diagram is intended only for basic information, binding dimensions receive at device delivery, or on request from the manufacturer.
- Bolt holes for duct connection (for one port): 4x M6

Call: 01494 525252

Visit: airflow.com



Airflow Developments Limited
Aidelle House, Lancaster Road,
Cressex Business Park,
High Wycombe, Buckinghamshire,
United Kingdom, HP12 3QP

E-mail: info@airflow.com
Telephone: +44 (0) 1494 525252
airflow.com

© Airflow Developments Limited. Airflow Developments Limited reserve the right, in the interests of continuous development, to alter specifications without prior notice. All orders are accepted subject to our conditions of sale which are available on request

80001153 – Issue 1 02/23

